

Monthly Council Report– March 2020

Water

- Total Gallons: 23,592,000
- Daily Average: 814,000
- Daily Max: 1,371,000
- New Meter Sets: 18
- Emergency repair of a 16" transmission watermain in front of Circle K.
- IDEM Inspection—Zero deficiencies.
- Becca Smith and Danny Powers passed the IFWA water Auditor Validator Exam.



16" Circle K Watermain Repair

Wastewater

- Total Gallons Treated: 31,586,000
- Daily Average: 1,089,000
- Daily Max: 1,997,000
- Emergency Repair of 10" sewage forcemain on main street.



10" Sewage Forcemain Damaged



10" Sewage Forcemain Repair

Inspections

- Utility Locates: 464
- Residential Inspections: 22

Streets

- Received Final Salt order of 600 Tons