

**MONTHLY COUNCIL REPORT — SEPTEMBER 2024**

**WATER**

- ◆ TOTAL GALLONS: 51,438
- ◆ DAILY MAX: 2,195
- ◆ DAILY AVERAGE: 1,715
- ◆ NEW METER SETS: 35
- ◆ REPLACED METERS: 32
- ◆ WATER MAIN BREAK IN ROYAL RUN
- ◆ EMPLOYEES PARTICIPATED IN THE OSHA CLASS
- ◆ ALL 3 MOTORS AND PUMPS HAVE BEEN REBUILT AT INDY RD BPS

Installing Pump into Indy Road Pump Station



**WASTEWATER**

- ◆ TOTAL GALLONS TREATED: 40.79 MG
- ◆ DAILY AVERAGE: 1.359 MG
- ◆ DAILY MAX FLOW : 1.926 MG



INSTALLING AN AIR RELIEF VALVE FOR THE NEW FORCE MAIN AT PEABODY

**INSPECTIONS**

- ◆ UTILITY LOCATES: 890
- ◆ BILLABLE INSPECTIONS HOURS: 179
- ◆ RESIDENTIAL INSPECTIONS: 19

**STREETS**

- ◆ CONTROLLED TRAFFIC FOR THE GRAVESITE RELOCATION
- ◆ TRIMMING TREES
- ◆ FILLING POT HOLES



Trimming Trees off 750 and 475



Water Main Break in Royal Run